



**DIVISION OF
ENVIRONMENTAL
QUALITY**

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

July 8, 2025

Michael B. Clayton, Director
NLRWU-Faulkner Lake
P.O. Box 17898
North Little Rock, AR 72117
Email Address: mclayton@nlrwu.com

RE: NLRWU-Faulkner Lake Inspection PDS# 133389 (Pulaski Co.)
AFIN: 60-00274 Permit No.: AR0020303

Dear Mr. Clayton:

On April 30, 2025, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the inspection report for any comments. If I can be of any assistance, please contact me at blain.sanders@arkansas.gov or (501) 412-6496.

Sincerely,

A handwritten signature in blue ink that reads "Blain Sanders".

Blain Sanders
Inspector, Office of Water Quality

Cc: meggleston@nlrwu.com

 ENVIRONMENTAL QUALITY	OFFICE OF WATER QUALITY INSPECTION REPORT				
	AFIN: 60-00274		PERMIT #: AR0020303		DATE: 4/30/2025
	COUNTY: 60 Pulaski		PDS #: 133389		MEDIA: WN
	GPS LAT: 34.73835 LONG: -92.178130 LOCATION: Entrance				
FACILITY INFORMATION			INSPECTION INFORMATION		
NAME: NLRWU- Faulkner Lake LOCATION: 7400 Baucum Pike CITY: Little Rock			FACILITY TYPE: 1 - Municipal INSPECTOR ID#: 123247 S - State		
			FACILITY EVALUATION RATING: 3 - Satisfactory INSPECTION TYPE: Compliance Evaluation		
			DATE(S): 4/30/2025 ENTRY TIME: 09:40 EXIT TIME: 10:35		
			PERMIT EFFECTIVE DATE: 6/1/2019 PERMIT EXPIRATION DATE: 5/31/2024		
RESPONSIBLE OFFICIAL					
NAME / TITLE: Michael B. Clayton / Director COMPANY: NLRWU- Faulkner Lake MAILING ADDRESS: P.O. Box 17898 CITY, STATE, ZIP: North Little Rock AR 72117 PHONE & EXT: / FAX: / EMAIL: mclayton@nlrwu.com			FAYETTEVILLE SHALE RELATED: N FAYETTEVILLE SHALE VIOLATIONS: N		
CONTACTED DURING INSPECTION: No			INSPECTION PARTICIPANTS NAME/TITLE/PHONE/FAX/EMAIL/ETC.: Marybeth Eggleston, EC&S Superintendent, NLRWU Chris Lumpkin, Technical Specialist, NLRWU Blain Sanders, Inspector, 501-682-0657		
AREA EVALUATIONS					
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)					
S	PERMIT	S	FLOW MEASUREMENT	N	STORMWATER
S	RECORDS/REPORTS	S	LABORATORY	S	FACILITY SITE REVIEW
S	OPERATION & MAINTENANCE	S	EFFLUENT/RECEIVING WATER	S	SELF-MONITORING PROGRAM
S	SAMPLING	S	SLUDGE HANDLING/DISPOSAL	N	PRETREATMENT
N	OTHER:				

SUMMARY OF FINDINGS
No violations were noted at the time of the inspection.
GENERAL COMMENTS
None, see checklists for any specific comments.

INSPECTOR'S SIGNATURE:  Blain Sanders	DATE: 5/18/2025
SUPERVISOR'S SIGNATURE:  Brent L. Walker	DATE: 6/30/2025

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE: Michael B. Clayton, Director P.O. Box 17898 North Little Rock, AR 72117	☒ Y ☐ N ☐ NA ☐ NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	☐ Y ☐ N ☒ NA ☐ NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT: Outfall 001	☒ Y ☐ N ☐ NA ☐ NE
4. ALL DISCHARGES ARE PERMITTED:	☒ Y ☐ N ☐ NA ☐ NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☒ Y ☐ N ☐ NA ☐ NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	☒ S ☐ M ☐ U ☐ NA ☐ NE
a. DATES AND TIME(S) OF SAMPLING:	☒ Y ☐ N ☐ NA ☐ NE
b. EXACT LOCATION(S) OF SAMPLING:	☒ Y ☐ N ☐ NA ☐ NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☒ Y ☐ N ☐ NA ☐ NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☒ Y ☐ N ☐ NA ☐ NE
e. RESULTS OF CALIBRATIONS:	☒ Y ☐ N ☐ NA ☐ NE
f. RESULTS OF ANALYSES:	☒ Y ☐ N ☐ NA ☐ NE
g. DATES AND TIMES OF ANALYSES:	☒ Y ☐ N ☐ NA ☐ NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☒ Y ☐ N ☐ NA ☐ NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	☒ S ☐ M ☐ U ☐ NA ☐ NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	☒ S ☐ M ☐ U ☐ NA ☐ NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☒ Y ☐ N ☐ NA ☐ NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. TREATMENT UNITS PROPERLY OPERATED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
2. TREATMENT UNITS PROPERLY MAINTAINED: Maintenance scheduled for various types of treatment equipment	☒ S ☐ M ☐ U ☐ NA ☐ NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED: 2 onsite backup generators; exercised weekly	☒ S ☐ M ☐ U ☐ NA ☐ NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE: Plant is on SCADA	☒ S ☐ M ☐ U ☐ NA ☐ NE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	☒ S ☐ M ☐ U ☐ NA ☐ NE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED: Spare parts kept onsite	☒ S ☐ M ☐ U ☐ NA ☐ NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	☐ Y ☐ N ☐ NA ☒ NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☒ Y ☐ N ☐ NA ☐ NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☒ Y ☐ N ☐ NA ☐ NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	☒ Y ☐ N ☐ NA ☐ NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	☒ Y ☐ N ☐ NA ☐ NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	☒ Y ☐ N ☐ NA ☐ NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	☐ Y ☒ N ☐ NA ☐ NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	☐ Y ☐ N ☒ NA ☐ NE

SECTION D: SAMPLING	
PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☒ Y ☐ N ☐ NA ☐ NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	☒ Y ☐ N ☐ NA ☐ NE
b. PROPER PRESERVATION TECHNIQUES USED:	☒ Y ☐ N ☐ NA ☐ NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☒ Y ☐ N ☐ NA ☐ NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	☐ Y ☐ N ☒ NA ☐ NE
SECTION E: FLOW MEASUREMENT	
PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: TYPE OF DEVICE: 4' Parshall Flume	☒ Y ☐ N ☐ NA ☐ NE
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☒ Y ☐ N ☐ NA ☐ NE
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED: Greyline Instruments OCF	☒ Y ☐ N ☐ NA ☐ NE
4. CALIBRATION FREQUENCY ADEQUATE: Calibration is done annually	☒ Y ☐ N ☐ NA ☐ NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES: Last known calibration was in 2024, but exact date was not determined	☒ Y ☐ N ☐ NA ☐ NE
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE: Monthly calibration checks are conducted	☒ Y ☐ N ☐ NA ☐ NE
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	☒ Y ☐ N ☐ NA ☐ NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☒ Y ☐ N ☐ NA ☐ NE
9. HEAD MEASURED AT PROPER LOCATION:	☒ Y ☐ N ☐ NA ☐ NE
SECTION F: LABORATORY	
PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☒ Y ☐ N ☐ NA ☐ NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	☐ Y ☐ N ☒ NA ☐ NE
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☒ Y ☐ N ☐ NA ☐ NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
5. DUPLICATE SAMPLES ARE ANALYZED $\geq 10\%$ OF THE TIME:	☒ Y ☐ N ☐ NA ☐ NE
6. SPIKED SAMPLES ARE ANALYZED $\geq 10\%$ OF THE TIME:	☒ Y ☐ N ☐ NA ☐ NE
7. COMMERCIAL LABORATORY USED: Wet testing only	☒ Y ☐ N ☐ NA ☐ NE
a. LAB NAME: Arkansas Analytical, Inc.	
b. LAB ADDRESS: 8100 National Drive Little Rock, AR 72209	
c. PARAMETERS PERFORMED: Wet testing	
8. BIOMONITORING PROCEDURES ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
a. PROPER ORGANISMS USED: Pimephales promelas (Fathead Minnow) & Ceriodaphnia dubia	☒ Y ☐ N ☐ NA ☐ NE
b. PROPER DILUTION SERIES FOLLOWED: 0%, 3%, 5%, 6%, 8%, 11%	☒ Y ☐ N ☐ NA ☐ NE
c. PROPER TEST METHODS AND DURATION:	☒ Y ☐ N ☐ NA ☐ NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED: All passing results	☐ Y ☐ N ☒ NA ☐ NE

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS							
BASED ON VISUAL OBSERVATIONS ONLY						☒ S ☐ M ☐ U ☐ NA ☐ NE	
DETAILS: Visual observation was conducted at the Parshall Flume structure.							
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
001	None	None	None	None	None	Clear	--
SECTION H: SLUDGE DISPOSAL							
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS						☒ S ☐ M ☐ U ☐ NA ☐ NE	
DETAILS: The facility is permitted to land apply municipal biosolids under Permit 4665-WR-4 or they may dispose of it at Two Pine Landfill. In 2024, a total of 8.7 million gallons and 3,575 fry tons were applied to over 214 acres.							
1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY:						☒ S ☐ M ☐ U ☐ NA ☐ NE	
2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503:						☒ S ☐ M ☐ U ☐ NA ☐ NE	
3. FOR LAND APPLIED SLUDGE, TYPE OF LAND APPLIED TO: (E.G., FOREST, AGRICULTURAL, PUBLIC CONTACT SITE):							
SECTION I: SAMPLING INSPECTION PROCEDURES							
SAMPLE RESULTS WITHIN PERMIT REQUIREMENTS						☐ S ☐ M ☐ U ☒ NA ☐ NE	
DETAILS:							
1. SAMPLES OBTAINED THIS INSPECTION:						☐ Y ☐ N ☒ NA ☐ NE	
2. TYPE OF SAMPLE: ☐ GRAB:___ ☐ COMPOSITE:___ METHOD:___ FREQUENCY:___							
3. SAMPLES PRESERVED:						☐ Y ☐ N ☒ NA ☐ NE	
4. FLOW PROPORTIONED SAMPLES OBTAINED:						☐ Y ☐ N ☒ NA ☐ NE	
5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:						☐ Y ☐ N ☒ NA ☐ NE	
6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:						☐ Y ☐ N ☒ NA ☐ NE	
7. SAMPLE SPLIT WITH PERMITTEE:						☐ Y ☐ N ☒ NA ☐ NE	
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:						☐ Y ☐ N ☒ NA ☐ NE	
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:						☐ Y ☐ N ☒ NA ☐ NE	
SECTION J: STORM WATER POLLUTION PREVENTION PLAN							
STORM WATER MANAGEMENT MEETS PERMIT REQUIREMENTS						☐ S ☐ M ☐ U ☐ NA ☒ NE	
DETAILS:							
1. SWPPP UPDATED AS NEEDED:___ DATE OF LAST UPDATE:___						☐ Y ☐ N ☐ NA ☒ NE	
2. SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS:						☐ Y ☐ N ☐ NA ☒ NE	
3. POLLUTION PREVENTION TEAM IDENTIFIED:						☐ Y ☐ N ☐ NA ☒ NE	
4. POLLUTION PREVENTION TEAM PROPERLY TRAINED:						☐ Y ☐ N ☐ NA ☒ NE	
5. LIST OF POTENTIAL POLLUTANT SOURCES:						☐ Y ☐ N ☐ NA ☒ NE	
6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:						☐ Y ☐ N ☐ NA ☒ NE	
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:						☐ Y ☐ N ☐ NA ☒ NE	
8. LIST OF STRUCTURAL BMPS:						☐ Y ☐ N ☐ NA ☒ NE	
9. LIST OF NON-STRUCTURAL BMPS:						☐ Y ☐ N ☐ NA ☒ NE	
10. BMPS PROPERLY OPERATED AND MAINTAINED:						☐ Y ☐ N ☐ NA ☒ NE	
11. INSPECTIONS CONDUCTED AS REQUIRED:						☐ Y ☐ N ☐ NA ☒ NE	

FLOW CALCULATION SHEET

Date:	4/30/2025	Time:	09:54		
Head in Inches:		Feet:	0.56'		
Type & Size of Primary Flow Measurement Device: 4' Parshall Flume					
Name & Model of Secondary Flow Measurement Device: Greyline Instruments OCF					
Date of last Calibration of Secondary Flow Device:				Unknown; calibrated annual and monthly calibration checks	
Recorded Flow at Date & Time Listed Above:		4.108 MGD		(Facility Flow Meter)	
Calculated Flow at Date & Time Listed Above:		4.142 MGD			
(Flow is calculated using flow charts in: ISCO Open Channel Flow Measurement Handbook-5 th Edition)					
% Error =	Recorded Value	-	Calculated Value	X 100	
	Calculated Value				
% Error =	4.108	-	4.142	X 100	
	4.142				
% Error =	-0.034	X 100			
	4.142				
% Error =	-0.008	X 100			
% Error =	-0.8	%			
Comments:	<u>Within ± 10% of true discharge. Calibration check on the influent flow meter was not conducted.</u>				

DMR Calculation Check

Reporting Period:	From	<u>2025</u>	<u>1</u>	<u>1</u>	To	<u>2025</u>	<u>1</u>	<u>31</u>
		Year	Month	Day		Year	Month	Day

Parameter Checked: TSS

	Loading Mass	Concentration	
	Mo. Avg. - lbs/day	Mo. Avg. - mg/l	7-day Avg. - mg/l
Reported Value:	<u>318.5</u>	<u>5.1</u>	<u>6.1</u>
Calculated Value:	<u>318.5</u>	<u>5.1</u>	<u>6.1</u>
Permit Value:	3002.4	30.0	45.0

If calculated value does not equal reported value, explain:

DMR Calculation Check

Reporting Period:	From	<u>2025</u>	<u>1</u>	<u>1</u>	To	<u>2025</u>	<u>1</u>	<u>31</u>
		Year	Month	Day		Year	Month	Day

Parameter Checked: BOD

	Loading Mass	Concentration	
	Mo. Avg. - lbs/day	Mo. Avg. - mg/l	7-day Avg. - mg/l
Reported Value:	<u>469.8</u>	<u>8.4</u>	<u>8.5</u>
Calculated Value:	<u>469.8</u>	<u>8.4</u>	<u>8.5</u>
Permit Value:	3002.4	30.0	45.0

If calculated value does not equal reported value, explain:

Office of Water Quality Photographic Evidence Sheet					
Location:	NLRWU- Faulkner Lake				
Photographer:	Blain Sanders	Date:	April 30, 2025	Time:	09:49
Witness:				Photo #:	1
Description:	Influent mechanical bar screening.				
					
Photographer:	Blain Sanders	Date:	April 30, 2025	Time:	09:49
Witness:				Photo #:	2
Description:	Influent structure.				
					

Office of Water Quality Photographic Evidence Sheet					
Location:	NLRWU- Faulkner Lake				
Photographer:	Blain Sanders	Date:	April 30, 2025	Time:	09:48
Witness:				Photo #:	3
Description:	Influent to the plant.				
					
Photographer:	Blain Sanders	Date:	April 30, 2025	Time:	09:48
Witness:				Photo #:	4
Description:	Influent Parshall flume.				
					

Office of Water Quality Photographic Evidence Sheet			
Location:	NLRWU- Faulkner Lake		
Photographer:	Blain Sanders	Date:	April 30, 2025
Time:	09:51		
Witness:			Photo #:
		5	
Description:	Primary clarifier #3.		
			
Photographer:	Blain Sanders	Date:	April 30, 2025
Time:	09:51		
Witness:			Photo #:
		6	
Description:	Weirs on the primary clarifier in good condition.		
			

Office of Water Quality Photographic Evidence Sheet				
Location: NLRWU- Faulkner Lake				
Photographer: Blain Sanders		Date: April 30, 2025	Time: 09:56	
Witness:		Photo #:		7
Description: Aeration basin #1.				
 A wide-angle photograph of a large, circular aeration basin. The water is dark and turbulent, with many white foam bubbles visible on the surface. In the background, there are concrete walls, some industrial buildings, and trees under a cloudy sky. An orange timestamp '04.30.2025 09:56' is visible in the bottom right corner of the photo.				
Photographer: Blain Sanders		Date: April 30, 2025	Time: 10:00	
Witness:		Photo #:		8
Description: Final clarifier #1.				
 A photograph of a large, circular final clarifier. The water is very calm and clear, reflecting the sky and clouds. The concrete walls of the basin are visible on the left side. In the background, there are some industrial buildings and trees. An orange timestamp '04.30.2025 10:00' is visible in the bottom right corner of the photo.				

Office of Water Quality Photographic Evidence Sheet			
Location:	NLRWU- Faulkner Lake		
Photographer:	Blain Sanders	Date:	April 30, 2025
Time:	10:01	Photo #:	9
Witness:			
Description:	Clarifier diversion chamber.		



Photographer:	Blain Sanders	Date:	April 30, 2025
Time:	10:02	Photo #:	10
Witness:			
Description:	One of eight chlorine contact chambers.		



Office of Water Quality Photographic Evidence Sheet					
Location: NLRWU- Faulkner Lake					
Photographer: Blain Sanders		Date: April 30, 2025		Time: 09:54	
Witness:				Photo #: 11	
Description: Effluent structure.					
					
Photographer: Blain Sanders		Date: April 30, 2025		Time: 09:54	
Witness:				Photo #: 12	
Description: 4 foot Parshall Flume.					
					

Office of Water Quality Photographic Evidence Sheet			
Location:	NLRWU- Faulkner Lake		
Photographer:	Blain Sanders	Date:	April 30, 2025
Time:	09:54		
Witness:			Photo #:
13			
Description:	Staff gauge reading 0.56 feet.		
			
Photographer:	Blain Sanders	Date:	April 30, 2025
Time:	09:53		
Witness:			Photo #:
14			
Description:	One of two onsite backup generators.		
			