



**DIVISION OF
ENVIRONMENTAL
QUALITY**

Sarah Huckabee Sanders
GOVERNOR

Shane E. Khoury
SECRETARY

11/03/2025

Bob Atkins, General Manager
West Memphis Utilities
P.O. Box 1868
West Memphis, AR 72301
Email Address: batkins@westmemphisar.gov

RE: West Memphis WWT Facility PDS: 133971
AFIN: 18-00879 Permit No.: AR0022039

Dear Mr. Atkins:

On August 21, 2025, I performed a Compliance Evaluation Inspection of the above referenced facility in accordance with the provisions of the Federal Clean Water Act, the Arkansas Water and Air Pollution Control Act, and the regulations promulgated thereunder. A copy of the inspection report is enclosed for your records.

No violations were noted at the time of the inspection. Please refer to the inspection report for any comments. If I can be of any assistance, please contact me at Sarah.Frasher@arkansas.gov or (501)837-2072.

Sincerely,

A handwritten signature in black ink, appearing to read "Sarah Frasher".

Sarah Frasher
Inspector, Office of Water Quality

Cc: Paul Holloway, West Memphis Utilities Director of Wastewater, pholloway@westmemphisar.gov

 ENVIRONMENTAL QUALITY	OFFICE OF WATER QUALITY INSPECTION REPORT		
	AFIN: 18-00879		PERMIT #: AR0022039
	DATE: 8/21/2025		
	COUNTY: 18 Crittenden	PDS #: 133971	MEDIA: WN
GPS LAT: 35.124212 LONG: -90.179016 LOCATION: Entrance			
FACILITY INFORMATION		INSPECTION INFORMATION	
NAME: West Memphis WWT Facility LOCATION: 502 South Loop Road CITY: West Memphis		FACILITY TYPE: 1 - Municipal	
		INSPECTOR ID#: 112347 S - State	
		FACILITY EVALUATION RATING: 3 - Satisfactory	
		INSPECTION TYPE: Compliance Evaluation	
		DATE(S): 8/21/2025	ENTRY TIME: 10:38
		EXIT TIME: 14:37	PERMIT EFFECTIVE DATE: 11/1/2024
		PERMIT EXPIRATION DATE: 10/31/2039	
RESPONSIBLE OFFICIAL			
NAME: / TITLE Bob Atkins / General Manager COMPANY: West Memphis Utilities MAILING ADDRESS: P.O. Box 1868 CITY, STATE, ZIP: West Memphis AR 72301 PHONE & EXT: / FAX: EMAIL: batkins@westmemphisar.gov		FAYETTEVILLE SHALE RELATED: N FAYETTEVILLE SHALE VIOLATIONS: N	
CONTACTED DURING INSPECTION: No			
AREA EVALUATIONS (S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not Applicable/Evaluated)			
S	PERMIT	S	FLOW MEASUREMENT
S	RECORDS/REPORTS	S	LABORATORY
S	OPERATION & MAINTENANCE	S	EFFLUENT/RECEIVING WATER
S	SAMPLING	S	SLUDGE HANDLING/DISPOSAL
N	OTHER:	N	STORMWATER
		S	FACILITY SITE REVIEW
		S	SELF-MONITORING PROGRAM
		N	PRETREATMENT
SUMMARY OF FINDINGS			
No violations were noted during the inspection.			

GENERAL COMMENTS

Construction is ongoing at the West Memphis WWTP for expansion and improvement of wastewater treatment. Some projects have been completed and have been added to the system while others are in the construction phase. The plant has added a grit chamber to the headworks (Photos 1-3) that is not yet operational. The previous drying beds for sludge have been transformed into a concrete pad for septic tank haulers (Photo 4). Four aerator wheels have been added to the expanded oxidation ditches (Photos 7-8). Another two oxidation ditches were in the process of being constructed during the inspection (Photo 9). The clarifiers are still operational (Photos 11-12) while the larger newer ones are under construction (Photos 13-15). Two of these old clarifiers will be used for sludge thickening in the future. A pump building for RAS and WAS pumps along with a new UV disinfection area is being constructed (Photos 16-19). These additions and improvements will help increase treatment and capacity for longer retention time of the wastewater.

A leak was observed from the dumpster roll-off (Photos 25-26). This was addressed in the Industrial Stormwater Inspection, ARR00C405, also performed with this inspection. Please view this permit in SEEK for details.

A Construction Stormwater Inspection was also performed at this site. Please view ARR158030 in SEEK for details.

INSPECTOR'S SIGNATURE:



Sarah Frasher

DATE: 10/31/2025

SUPERVISOR'S SIGNATURE:



Jason Bolenbaugh

DATE: 11/3/2025

SECTION A: PERMIT VERIFICATION	
PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE:	☒ Y ☐ N ☐ NA ☐ NE
2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES:	☒ Y ☐ N ☒ NA ☐ NE
3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
4. ALL DISCHARGES ARE PERMITTED:	☒ Y ☐ N ☐ NA ☐ NE
SECTION B: RECORDKEEPING AND REPORTING EVALUATION	
RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS:	
1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRS:	☒ Y ☐ N ☐ NA ☐ NE
2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE:	☒ S ☐ M ☐ U ☐ NA ☐ NE
a. DATES AND TIME(S) OF SAMPLING:	☒ Y ☐ N ☐ NA ☐ NE
b. EXACT LOCATION(S) OF SAMPLING:	☒ Y ☐ N ☐ NA ☐ NE
c. NAME OF INDIVIDUAL PERFORMING SAMPLING:	☒ Y ☐ N ☐ NA ☐ NE
d. ANALYTICAL METHODS AND TECHNIQUES:	☒ Y ☐ N ☐ NA ☐ NE
e. RESULTS OF CALIBRATIONS:	☒ Y ☐ N ☐ NA ☐ NE
f. RESULTS OF ANALYSES:	☒ Y ☐ N ☐ NA ☐ NE
g. DATES AND TIMES OF ANALYSES:	☒ Y ☐ N ☐ NA ☐ NE
h. NAME OF PERSON(S) PERFORMING ANALYSES:	☒ Y ☐ N ☐ NA ☐ NE
3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE:	☒ S ☐ M ☐ U ☐ NA ☐ NE
4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR:	☒ S ☐ M ☐ U ☐ NA ☐ NE
5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA:	☒ Y ☐ N ☐ NA ☐ NE
SECTION C: OPERATIONS AND MAINTENANCE	
TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED	☒ S ☐ M ☐ U ☐ NA ☐ NE
DETAILS: <u>Treatment of wastewater during construction activity.</u>	
1. TREATMENT UNITS PROPERLY OPERATED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
2. TREATMENT UNITS PROPERLY MAINTAINED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE:	☐ S ☐ M ☐ U ☐ NA ☐ NE
5. ALL NEEDED TREATMENT UNITS IN SERVICE:	☒ S ☐ M ☐ U ☐ NA ☐ NE
6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED:	☒ S ☐ M ☐ U ☐ NA ☐ NE
8. OPERATION AND MAINTENANCE MANUAL AVAILABLE:	☐ Y ☐ N ☒ NA ☐ NE
9. STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED:	☒ Y ☐ N ☐ NA ☐ NE
10. PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED:	☒ Y ☐ N ☐ NA ☐ NE
11. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR:	☐ Y ☒ N ☐ NA ☐ NE
12. IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED:	☐ Y ☐ N ☒ NA ☐ NE
13. HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS:	☒ Y ☐ N ☐ NA ☐ NE
14. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT:	☐ Y ☒ N ☐ NA ☐ NE
15. IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT:	☐ Y ☐ N ☒ NA ☐ NE

SECTION D: SAMPLING**PERMITTEE SAMPLING MEETS PERMIT REQUIREMENTS**☒S ☐M ☐U ☐NA ☐NE**DETAILS:**

1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES:	☒ Y ☐ N ☐ NA ☐ NE
3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT:	☒ Y ☐ N ☐ NA ☐ NE
6. SAMPLE COLLECTION PROCEDURES ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
a. SAMPLES REFRIGERATED DURING COMPOSITING:	☒ Y ☐ N ☐ NA ☐ NE
b. PROPER PRESERVATION TECHNIQUES USED:	☒ Y ☐ N ☐ NA ☐ NE
c. CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136:	☒ Y ☐ N ☐ NA ☐ NE
7. IF MONITORING IS PERFORMED MORE OFTEN THAN REQUIRED ARE RESULTS REPORTED ON THE DMR:	☒ Y ☐ N ☐ NA ☐ NE

SECTION E: FLOW MEASUREMENT**PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS**☒S ☐M ☐U ☐NA ☐NE**DETAILS:**

1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED: <u>Yes</u> TYPE OF DEVICE: <u>ISCO Signature Flowmeter</u>	☒ Y ☐ N ☐ NA ☐ NE
2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED:	☒ Y ☐ N ☐ NA ☐ NE
3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED:	☒ Y ☐ N ☐ NA ☐ NE
4. CALIBRATION FREQUENCY ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
5. RECORDS MAINTAINED OF CALIBRATION PROCEDURES:	☒ Y ☐ N ☐ NA ☐ NE
6. CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE:	☒ Y ☐ N ☐ NA ☐ NE
7. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE:	☒ Y ☐ N ☐ NA ☐ NE
8. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES:	☒ Y ☐ N ☐ NA ☐ NE
9. HEAD MEASURED AT PROPER LOCATION:	☒ Y ☐ N ☐ NA ☐ NE

SECTION F: LABORATORY**PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS**☒S ☐M ☐U ☐NA ☐NE**DETAILS:**

1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(B) FOR SLUDGES) :	☒ Y ☐ N ☐ NA ☐ NE
2. IF ALTERNATIVE ANALYTICAL PROCEDURES ARE USED, PROPER APPROVAL HAS BEEN OBTAINED:	☒ Y ☐ N ☐ NA ☐ NE
3. SATISFACTORY CALIBRATION AND MAINTENANCE OF INSTRUMENTS AND EQUIPMENT:	☒ Y ☐ N ☐ NA ☐ NE
4. QUALITY CONTROL PROCEDURES ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
5. DUPLICATE SAMPLES ARE ANALYZED $\geq 10\%$ OF THE TIME:	☒ Y ☐ N ☐ NA ☐ NE
6. SPIKED SAMPLES ARE ANALYZED $\geq 10\%$ OF THE TIME:	☒ Y ☐ N ☐ NA ☐ NE
7. COMMERCIAL LABORATORY USED:	☒ Y ☐ N ☐ NA ☐ NE
a. LAB NAME: <u>Waypoint Analytical</u>	
b. LAB ADDRESS: <u>Memphis, TN</u>	
c. PARAMETERS PERFORMED: <u>WET Testing, Total Phosphorus, Nitrate + Nitrite Nitrogen</u>	
8. BIOMONITORING PROCEDURES ADEQUATE:	☒ Y ☐ N ☐ NA ☐ NE
a. PROPER ORGANISMS USED:	☒ Y ☐ N ☐ NA ☐ NE
b. PROPER DILUTION SERIES FOLLOWED:	☒ Y ☐ N ☐ NA ☐ NE
c. PROPER TEST METHODS AND DURATION:	☒ Y ☐ N ☐ NA ☐ NE
d. RETESTS AND/OR TRE PERFORMED AS REQUIRED:	☒ Y ☐ N ☐ NA ☐ NE

SECTION G: EFFLUENT/RECEIVING WATERS OBSERVATIONS							
BASED ON VISUAL OBSERVATIONS ONLY						☒ S ☐ M ☐ U ☐ NA ☐ NE	
DETAILS:							
OUTFALL #:	OIL SHEEN	GREASE	TURBIDITY	VISIBLE FOAM	FLOATING SOLIDS	COLOR	OTHER
001	None	None	Medium	None	None	Green	--
SECTION H: SLUDGE DISPOSAL							
SLUDGE DISPOSAL MEETS PERMIT REQUIREMENTS						☒ S ☐ M ☐ U ☐ NA ☐ NE	
DETAILS:							
1. SLUDGE MANAGEMENT ADEQUATE TO MAINTAIN EFFLUENT QUALITY:						☒ S ☐ M ☐ U ☐ NA ☐ NE	
2. SLUDGE RECORDS MAINTAINED AS REQUIRED BY 40 CFR 503:						☒ S ☐ M ☐ U ☐ NA ☐ NE	
3. FOR LAND APPLIED SLUDGE, TYPE OF LAND APPLIED TO: (E.G., FOREST, AGRICULTURAL, PUBLIC CONTACT SITE):							
SECTION I: SAMPLING INSPECTION PROCEDURES							
SAMPLE RESULTS WITHIN PERMIT REQUIREMENTS						☐ S ☐ M ☐ U ☒ NA ☐ NE	
DETAILS:							
1. SAMPLES OBTAINED THIS INSPECTION:						☐ Y ☐ N ☒ NA ☐ NE	
2. TYPE OF SAMPLE: ☐ GRAB:___ ☐ COMPOSITE:___ METHOD:___ FREQUENCY:___							
3. SAMPLES PRESERVED:						☐ Y ☐ N ☒ NA ☐ NE	
4. FLOW PROPORTIONED SAMPLES OBTAINED:						☐ Y ☐ N ☒ NA ☐ NE	
5. SAMPLE OBTAINED FROM FACILITY'S SAMPLING DEVICE:						☐ Y ☐ N ☒ NA ☐ NE	
6. SAMPLE REPRESENTATIVE OF VOLUME AND NATURE OF DISCHARGE:						☐ Y ☐ N ☒ NA ☐ NE	
7. SAMPLE SPLIT WITH PERMITTEE:						☐ Y ☐ N ☒ NA ☐ NE	
8. CHAIN-OF-CUSTODY PROCEDURES EMPLOYED:						☐ Y ☐ N ☒ NA ☐ NE	
9. SAMPLES COLLECTED IN ACCORDANCE WITH PERMIT:						☐ Y ☐ N ☒ NA ☐ NE	
SECTION J: STORM WATER POLLUTION PREVENTION PLAN							
STORM WATER MANAGEMENT MEETS PERMIT REQUIREMENTS						☐ S ☐ M ☐ U ☒ NA ☐ NE	
DETAILS:							
1. SWPPP UPDATED AS NEEDED:___ DATE OF LAST UPDATE:___						☐ Y ☐ N ☒ NA ☐ NE	
2. SITE MAP INCLUDING ALL DISCHARGES AND SURFACE WATERS:						☐ Y ☐ N ☒ NA ☐ NE	
3. POLLUTION PREVENTION TEAM IDENTIFIED:						☐ Y ☐ N ☒ NA ☐ NE	
4. POLLUTION PREVENTION TEAM PROPERLY TRAINED:						☐ Y ☐ N ☒ NA ☐ NE	
5. LIST OF POTENTIAL POLLUTANT SOURCES:						☐ Y ☐ N ☒ NA ☐ NE	
6. LIST OF POTENTIAL SOURCES AND PAST SPILLS AND LEAKS:						☐ Y ☐ N ☒ NA ☐ NE	
7. ALL NON-STORM WATER DISCHARGES ARE AUTHORIZED:						☐ Y ☐ N ☒ NA ☐ NE	
8. LIST OF STRUCTURAL BMPs:						☐ Y ☐ N ☒ NA ☐ NE	
9. LIST OF NON-STRUCTURAL BMPs:						☐ Y ☐ N ☒ NA ☐ NE	
10. BMPs PROPERLY OPERATED AND MAINTAINED:						☐ Y ☐ N ☒ NA ☐ NE	
11. INSPECTIONS CONDUCTED AS REQUIRED:						☐ Y ☐ N ☒ NA ☐ NE	

DMR Calculation Check

Reporting Period:	From	<u>2025</u>	<u>02</u>	<u>01</u>	To	<u>2025</u>	<u>02</u>	<u>28</u>
		Year	Month	Day		Year	Month	Day

Parameter Checked: TSS

	Loading Mass Mo. Avg. - lbs/day	Concentration Monthly Mo. Avg. - mg/l	7-day Avg. - mg/l
Reported Value:	<u>1,266</u>	<u>20.4</u>	<u>24.9</u>
Calculated Value:	<u>1,266</u>	<u>20.4</u>	<u>24.9</u>
Permit Value:	1,576.3	30.0	45.0

If calculated value does not equal reported value, explain: Equal

DMR Calculation Check

Reporting Period:	From	<u>2025</u>	<u>05</u>	<u>01</u>	To	<u>2025</u>	<u>05</u>	<u>31</u>
		Year	Month	Day		Year	Month	Day

Parameter Checked: BOD

	Loading Mass Mo. Avg. - lbs/day	Concentration Monthly Mo. Avg. - mg/l	7-day Avg. - mg/l
Reported Value:	537	8.9	11.4
Calculated Value:	537	8.9	11.4
Permit Value:	1576.3	30	45

If calculated value does not equal reported value, explain: Equal

Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Time:	11:01	Witness:	None
Photo #:	1	Description:	View of the headworks to the plant.
			
Photographer:	Sarah Frasher	Date:	8/21/2025
Time:	11:11	Witness:	None
Photo #:	2	Description:	View of the newly constructed grit chamber.
			

Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:11
		Photo #:	3
Description:	View of the bar screen.		
			
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:12
		Photo #:	4
Description:	View of the concrete pad for septic haulers.		
			

Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:13
		Photo #:	5
Description:	View of the EQ basin.		



Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:18
		Photo #:	6
Description:	Overview of the oxidation ditches.		



Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:09
		Photo #:	7
Description:	View of the oxidation ditch. Note the addition of the wheel aerators.		
			
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:08
		Photo #:	8
Description:	Close up view of the wheel aerators.		
			

Office of Water Quality Photographic Evidence Sheet					
Location:	West Memphis WWT Facility				
Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:04
Witness:	None			Photo #:	9
Description:	View of the construction on the other oxidation ditches.				
					
Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:19
Witness:	None			Photo #:	10
Description:	View of the sludge thickener.				
					

Office of Water Quality Photographic Evidence Sheet					
Location:	West Memphis WWT Facility				
Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:21
Witness:	None			Photo #:	11
Description:	View of the clarifier.				
					
Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:24
Witness:	None			Photo #:	12
Description:	Close-up view of the clarifier.				
					

Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:24
		Photo #:	13
Description:	View of the constructed clarifiers.		
			
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	12:16
		Photo #:	14
Description:	View of the construction of the clarifier.		
			

Office of Water Quality Photographic Evidence Sheet

Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	12:18
		Photo #:	15
Description:	View of the inside of the constructed clarifier.		



Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:21
		Photo #:	16
Description:	View of the construction for the pump building and UV structure.		



Office of Water Quality Photographic Evidence Sheet

Location:	West Memphis WWT Facility				
Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:39
Witness:	None			Photo #:	17
Description:	View of the constructed UV structure.				



Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:39
Witness:	None			Photo #:	18
Description:	View of the constructed pump house.				



Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:40
		Photo #:	19
Description:	View of the WAS and RAS pumps.		



Photographer:	Sarah Frasher	Date:	8/21/2025	Time:	11:43
Witness:	None			Photo #:	20
Description:	View of the sampler for composite sampling.				



Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	12:04
		Photo #:	21
Description:	View of the peracetic acid tote used for disinfection.		
			
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:47
		Photo #:	22
Description:	View of the building for the belt filter press.		
			

Office of Water Quality Photographic Evidence Sheet

Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:48
		Photo #:	23
Description:	View of the belt filter press.		



Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:47
		Photo #:	24
Description:	View of the roll-off dumpster for the waste cakes from the belt filter press.		



Office of Water Quality Photographic Evidence Sheet			
Location: West Memphis WWT Facility			
Photographer:	Sarah Frasher	Date:	8/21/2025
Witness:	None	Time:	11:48
Photo #:		25	
Description: View of the side of the roll-off. Note the broken area.			
			
Photographer:		Sarah Frasher	Date:
Witness:		None	Time:
Photo #:		26	
Description: View of the leakage from the roll-off dumpster.			
			

Office of Water Quality Photographic Evidence Sheet			
Location:	West Memphis WWT Facility		
Photographer:	Sarah Frasher	Date:	8/21/2025
Time:	11:43		
Witness:	None	Photo #:	27
Description:	View of the outfall structure. Note the color of the water.		
			