

Noland Percent Removal												
Date	Influent Flow MGD	Effluent Flow MGD	Influent CBOD mg/L	Influent CBOD Load Lbs	Effluent CBOD mg/L	Effluent CBOD Load Lbs	Effluent CBOD Percent Removal %	Influent TSS mg/l	Influent TSS Load Lbs	Effluent TSS mg/L	Effluent TSS Load Lbs	Effluent TSS Percent Removal %
3/1/2025	4.37	4.64										
3/2/2025	5.46	6.70										
3/3/2025	5.45	6.99			4	204		148	6,723	4	210	98
3/4/2025	6.12	5.93	228	11,643	4	188	98			3	129	
3/5/2025	12.68	5.89						186	19,674			
3/6/2025	10.87	10.87			4	326				11	1,020	
3/7/2025	8.54	10.43						160	11,401			
3/8/2025	6.83	9.26										
3/9/2025	5.58	7.89										
3/10/2025	6.03	8.67			5	325		132	6,633	5	354	96
3/11/2025	9.42	8.60	201	15,778	4	316	98			6	409	
3/12/2025	6.51	7.21			4	241		196	10,638	6	3,307	72
3/13/2025	5.39	7.20										
3/14/2025	3.95	9.06						168	5,527			
3/15/2025	4.58	7.98										
3/16/2025	4.99	7.85										
3/17/2025	4.70	6.86			4	240		144	5,639	4	206	98
3/18/2025	5.70	6.57	255	12,122	4	192	99			4	236	
3/19/2025	4.86	6.62			5	265		274	11,101	4	204	99
3/20/2025	4.99	0.00										
3/21/2025	4.22							224	7,882			
3/22/2025	4.40	3.55										
3/23/2025	5.24	6.46										
3/24/2025	4.04	6.30			4	226		312	10,515	3	173	99
3/25/2025	3.34	6.23	271	7,548	5	249	98			5	234	
3/26/2025	2.71	5.63			6	268		388	8,779	4	207	99
3/27/2025	3.97	6.63										
3/28/2025	2.91	6.74						224	5,429			
3/29/2025	5.08	6.74										
3/30/2025	3.44	6.54										
3/31/2025	4.47	6.39			6	320		204	7,600	3	176	98
Average	5.51	6.88	239	11,773	4	258	98.3	212	9,042	5	528	94.8