

NON-COMPLIANCE REPORT

Arkansas Department of Energy & Environment
Division of Environmental Quality
Office of Water Quality, Enforcement Section
5301 Northshore Drive, North Little Rock, AR 72118

RE: Permit No: AR0020273 Discharge Number: 001
Facility: City of Siloam Springs Water Pollution Control Facility
Address: 975 Anderson Avenue
City: Siloam Springs State: AR Zip: 72761
Contact: Josh Napier Phone: 479.238.0935

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
04/02/2026	7-Day Average Ammonia [as N]		4.34 mg/L	3.9 mg/L

We feel this problem was due to:

~~super wasting digesters and air issues with digesters~~


We plan on correcting the problem in this manner:

~~super wasting is complete and the valves were adjusted to better disperse air between digester operations~~

Time estimated that it will take to correct problem:

~~problem has self corrected~~

Sincerely,



Submitted By:

05/21/2026

Date

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)