

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021482 Discharge Number: 001

Facility: City of Van Buren Southplant

Address: 2806 Bryan Road

City: Van Buren State: AR Zip: 72957

Contact: Steve Dufresne, Director of Utilities Phone: 479-474-5067

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
1/29/25	BOD		46 (7 day)	45 (7 day)

We feel this problem was due to:

When checking the plant on 1/7/2025 the blower 201 was found not working. The machine shop was contacted the same day and found the bearing was damaged.


We plan on correcting the problem in this manner:

The blower was taken to the machine shop on 1/16/2025 and the machine shop ordered the bearing. The machine was contacted on 1/29/2025 and 2/5/2025 checking on progress of the repairs. The machine shop had not received the bearings for the repair at this time. We will be ordering a new blower and motor to have a back up to change out in the future.

Time estimated that it will take to correct problem:

The machine shop received the bearing and completed the repairs. Blower 201 was reinstalled on 2/10/2025. The plant is currently in compliance.

Sincerely,



Authorized Signature

Date 2/21/2025