

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021482 Discharge Number: 001

Facility: City of Van Buren Southplant

Address: 2806 Bryan Road

City: Van Buren State: AR Zip: 72957

Contact: Steve Dufresne, Director of Utilities Phone: 479-474-5067

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
7/1-6/24	CBOD		54	40 (monthly)
7/1-6/24	TSS		50	45 (weekly)
7/1-6/24	NH3-N		7	5 (weekly)
7/1-6/24	NH3-N		27	7.5 (weekly)
7/24/24	NH3-N	191		166.8 (monthly)

We feel this problem was due to:

The diffusers were repaired on 7/9/2024 by JPS contractors. The wwtp is still recovering from not having air.


We plan on correcting the problem in this manner:

The major upgrade to the diffuser system are scheduled for the week of 9/24/24 by JPS.

Time estimated that it will take to correct problem:

Parts have been ordered and contractor has been scheduled for the week of 9/22/24.

Sincerely,


Authorized Signature

8/22/2024
Date