



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

May 22, 2024

Ms. Rachel Wilcox
Compliance Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Wilcox:

This letter shall serve as the noncompliance report (NCR) for April 2024 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Peracetic Acid (PAA) – Inst. Max
2. Coliform, Fecal – 7-Day Avg. Max

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- PAA: The PCW had to start operating at a higher residual to achieve satisfactory fecal coliform counts. There were two different instances where demand changed in the effluent, PAA dosage did not get adjusted in a timely manner, and the residual was higher than our limit the next day. Fecal Coliform: This violation was due to the PAA not having enough detention time for proper disinfection. These issues have been corrected and the PCW is back in compliance.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,

A handwritten signature in blue ink, appearing to read "Steve Mallett", is written over a horizontal line.

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com