



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

April 23, 2025

Ms. Rachel Wilcox
Compliance Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Wilcox:

This letter shall serve as the noncompliance report (NCR) for March 2025 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – 7-Day Avg. Max
2. Coliform, Fecal General – 7-Day Avg. Max (Geo Mean)
3. BOD, Carbonaceous (5-day) – Mon. Avg. Con.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- A mixture of high sludge blanket levels in our secondary clarifiers, greater than design flow through the plant at times due to local rainfall causing our secondary clarifiers to wash-out. This created turbid effluent and inhibited the disinfection process. We also experienced possible organic overloading, process imbalances, and old sludge accumulation that contributed to violations. Adjustments have been made to the PCW and is back in compliance.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,

A handwritten signature in blue ink, appearing to read "Steve Mallett".

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com