



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

June 20, 2023

Ms. Christina Brown
Enforcement Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Brown:

This letter shall serve as the noncompliance report (NCR) for May 2023 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. pH – Inst. Min.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- One of the biggest local food industries (Con-Agra) shut down for a week due to maintenance. This affected the loading/pH to the PCW. The staff added chemical nutrients to the treatment process to counter act the loss of loading during that time and was able to get the pH back into compliance. The PCW has stayed in compliance since this event.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,

A handwritten signature in blue ink, appearing to read "Steve Mallett".

Steve Mallett
Chief Executive Officer, City Corporation

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com