



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

December 19, 2023

Ms. Kristen Graham
Compliance Analyst
Water Division/Enforcement Branch
Division of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Ms. Graham:

This letter shall serve as the noncompliance report (NCR) for November 2023 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – 7-Day Avg.

The above violations were caused by the following events at the Pollution Control Works (PCW) during this reporting period.

- Local rain events that totaled over three inches leading into the month of November. This plus poor settling sludge in the secondary clarifiers, which led to turbid effluent out of the clarifiers. The PCW has since been back in compliance.

Should you have any questions or need other info please contact Greg Kremers, Wastewater Operations Director at 479-968-2080 ext. 236.

Sincerely,

A handwritten signature in black ink, appearing to read "Steve Mallett", written over a horizontal line.

Steve Mallett
Chief Executive Officer

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com