

Conformation Number: 7bf401a4-bfbd-4a3a-b398-f8927b5781d6

The Nashville Wastewater Plant relief pond had an overflow due to rainfall on April 26, 2025. The City of Nashville received rainfall. The relief pond started to overflow on April 27, 2025 at 9:55 A.M. and did not stop until April 28, 2025 at 8:27 A.M. The volume of the overflow was 0.03538 MGD. There was no evidence of adverse Health or Environmental Impact. The overflow water went to a ditch. If you have any question please feel free to call me.

Kevin Funderburk

Chief Wastewater Operator

Phone: (870)557-5704