



City of Nashville

Larry Dunaway, Mayor



February 6, 2025

ADEQ
5301 Northshore Dr
North Little Rock, AR 72118

Re: Nashville Wastewater Treatment Plant

To Whom It May Concern,

At 11:00 a.m. on February 5, 2025, a breach of the levee of our equalization basin was found. The flow through the breach was stopped at 5:30 p.m. on the same day. The flow is estimated to be about 200 gpm for an approximate total volume of 0.139MGD. The flow was discharged to our outfall ditch, leading to Mine Creek. There is no anticipated environmental impact.

If you have any questions or concerns, contact Kevin Funderburk, Chief Operator, at 870-557-5704 or Larry Dunaway, Mayor, at 870-557-1953.

Thank you

Larry Dunaway
Mayor
City of Nashville