

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022039 Discharge Number: 01
Facility: WEST MEMPHIS WASTEWATER TREATMENT FACILITY
Address: 502 SOUTH LOOP
City: WEST MEMPHIS State: AR Zip: 72301
Contact: PAUL HOLLOWAY Phone: 870-732-7600

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 2025	Monthly Avg.	B.O.D.	30.2	30
March 2025	Monthly Avg.	TSS	32.6	30

We feel this problem was due to:

We had a under loading of our plant due to construction of Ditch 1. We had to put half of our flow into our pond as to not flood Ditch 1 while men were working in it.

We plan on correcting the problem in this manner:

Ditch 1 is back in service and working.

Time estimated that it will take to correct problem:

None

Sincerely,


Submitted By:

4/15/2025
Date

☒ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)