

NPDES Permit No. AR0033723
City of El Dorado – South Plant
010S Outfall
Non-Compliance Report
November 2024

All parameters sampled at Outfall 010S were within permit limits except for the following:

Outfall	Parameter	Date	Permit Limit	Sample Result
010S	Total Suspended Solids (TSS)	11/05/2024	Daily Maximum 45 mg/L	68 mg/L

Total Suspended Solids:

There were no obvious indicators for elevated TSS levels on November 5th. TSS concentration values were 12 mg/l on November 4th and <10 mg/l on November 6th. TSS concentrations were in compliance the remainder of the month. The City of El Dorado will continue to carefully monitor the treatment system and maintain appropriate TSS concentrations.