



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/2/25

Location of event: Gulpha Creek

Sample collection date: 4/10/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0947	E. Coli – 184.2 cfu per 100mls
Site 3:	0953	E. Coli – 81.6 cfu per 100mls
Site 4:	0958	E. Coli – 93.4 cfu per 100mls
Site 5:	1007	E. Coli – 30.5 cfu per 100mls

Results for samples taken 4/8/25 & 4/10/25 were below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5. No further testing needed.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs