

Amanda Blackmon (adpce.ad)

From: Harold Mauldin <HMAuldin@cityhs.net>
Sent: Friday, April 11, 2025 1:32 PM
To: EE Water Enforcement Report; Leslie Allen-Daniel (adpce.ad)
Cc: Monty Ledbetter; Bill Burrough
Subject: Blending Valve Closed April 11, 2025

Leslie,

Confirmation Number: 0ab371d9-86e6-4207-b783-b60a0abd10b3

The Davidson Wastewater Treatment Plant (Permit Number AR0033880) was able to close the Blending Valve today (April 11, 2025) at 8:30am. From April 3, 2025, to April 11, 2025, approximately 120 million gallons of water went through blending and into cloth filtration and UV disinfection. if you have any questions, please let me know.

Thank you,

Harold Mauldin
Facilities Operations Manager
City of Hot Springs
(501) 621-5041 Ex. 2860

