

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August 2024	Total Phosphorus	128.79 lbs.		100.1 lbs.

We feel this problem was due to: Short-Circuiting in Secondary Clarifiers. Clarifier 1 and 2 were taken down for maintenance in during the first two weeks of the month. The increase in sludge to the online clarifiers caused a shock to the process.

We plan on correcting the problem in this manner: The issue is corrected by the completion of the weir gate install and sludge lines. We are now able to use the secondary clarification to their fullest capacity.

Time estimated that it will take to correct problem: The issue has already been settled.

Sincerely,

Harold Mauldin

Submitted By: ☐

September 6, 2024
Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)