

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDS Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Davidson Wastewater Treatment Plant

Address: 320 Davidson Drive City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
February 2025	Total Suspended Solids (Month)	2526 Lbs.		1501.2 Lbs.
February 1, 2025	Total Suspended Solids (7 Day)		27.6 Mg/l	22.5 Mg/l
February 2025	C-BOD5 (Month)	2172 Lbs.		1000.8 Lbs.
February 2025	C-BOD5 (Month)		12.33 Mg/l	10.0 Mg/l
February 1, 2025	C-BOD5 (7-Day)		20.51 Mg/l	15.0 Mg/l
February 1, 2025	Fecal Coliform (7-Day)		3008 Geo. Mean	2000 Geo. Mean

We feel this problem was due to: High Flows end of January and into February. Equalization Pond filled to capacity. We were forced to blend flow.

We plan on correcting the problem in this manner: Flows have returned to normal.

Time estimated that it will take to correct problem: Flow will be inhibited from time to time as improvement are made to the treatment plant. Work will continue through the rest of the year.

Sincerely,



Submitted By:



March 12, 2025

Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)