

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDS Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
January 2025	Total Suspended Solids	2099 Lbs.		1501.2 Lbs.
January 2025	Total Suspended Solids		17.4 Mg/l	15.0 Mg/l
January 2025	C-BOD5	1323.63 Lbs.		1000.8 Lbs.
January 2025	C-BOD5		11.27 Mg/l	10.0 Mg/l

We feel this problem was due to:

Two High Flow (Blended Flow) Events during the month of January

We plan on correcting the problem in this manner:

Increasing Treatment Capacity from 12MGD to 16MGD

Time estimated that it will take to correct problem:

Construction is underway to help with wet weather events with will continue throughout the year and into 2026.

Sincerely,



Submitted By:



February 13, 2025

Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)