

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125


Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
June 1, 2024	Fecal Coliform		2075.13 cfu's	<200 cfu's

We feel this problem was due to: High Flows resulted in blended flows from previous month. Clarifier #4 still offline for maintenance.

We plan on correcting the problem in this manner: Cloth Filters and UV Disinfection cleaned after high flows/rain event.

Time estimated that it will take to correct problem: Fecal Coliform levels have returned to well below permit range.

Sincerely,



Submitted By:

☒



Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)