

Kayla L. Grabinski

From: Harold Mauldin <HMAuldin@cityhs.net>
Sent: Tuesday, April 8, 2025 5:04 PM
To: EE Water Enforcement Report; Leslie Allen-Daniel (adpce.ad)
Cc: Monty Ledbetter; Gordon Yates
Subject: April 3, 2025, Blending Events Continues

Leslie,

Confirmation Number: 0ab371d9-86e6-4207-b783-b60a0abd10b3

The Davidson Wastewater Treatment Plant (Permit Number Ar0033880) began blending flow on April 3, 2025 at 8:00 am. From April 3, 2025, to April 8, 2025, approximately 106 million gallons have gone through the blending valve and into cloth filtration and UV disinfection. Almost 12 inches of rain fell between April 2 and April 6, 2025. High flows continue so the Blending Valve remains open. I will follow up with another email, once the flows subside.

Thank you,

Harold Mauldin
Facilities Operations Manager
City of Hot Springs
(501) 621-5041 Ex. 2860

