



CITY OF HOT SPRINGS

Utilities Department

780 Adams Street

Hot Springs, Arkansas 71901

June 14, 2025

Sent via Email

Leslie Allen-Daniel
Enforcement Analyst – Water Division
Arkansas Energy & Environment – Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

**RE: City of Hot Springs Utilities
Permit No. AR0033880 / AFIN 26-00145
Progress Report – Hot Springs Creek Pump Station**

Dear Ms. Allen-Daniel,

City Staff has taken delivery of all the equipment required for the pump Station upgrades/replacement parts.

Staff is still awaiting a proposal from Max Foote Construction Company, LLC for the demolition of the old pumps, motors and valves and replacing them with the new equipment. We should have this by the end of this week. Installation will occur within the next couple of months.

Five SSOs occurred in the Hot Springs Creek Pump Station area. These were recorded and reported to ADEQ after separate 2.0-inch rainfall events. Lab results along with environmental cleanup documentation are attached.

Should you have any questions, please contact me at mledbetter@cityhs.net.

Sincerely,

Monty Ledbetter
Utilities Director

Attachments: Lab Results; Documentation of Public Notice Signage; Environmental Cleanup Activities

cc: **City of Hot Springs** - Bill Burrough, City Manager; Denny McPhate, Deputy City Manager; Harold Mauldin, Wastewater Facilities Operations Manager; Todd Piller, Capital Project Manager;
Consultants - Craig Johnson, Crist
Arkansas Energy & Environment Division of Environmental Quality – Richard Healey

MAY SSO REPORT for Manholes 1866, 1865 and 3728

Hot Springs Creek Pump Station

Manhole 1866

362 Fontana Road

Overflow Date: 5/6/2025
End Date: 5/6/2025
Cause: Rainfall, Equipment
Discharge: Approximately 67,500 gallons discharged to Hot Springs Creek
Actions Taken: Hydro Cleaned, Environmental Cleanup
Code Red Issued: 5/7/2025
Code Red Cancelled: 5/13/2025

Manhole 3728

107 Forest View Court

Overflow Date: 5/6/2025
End Date: 5/6/2025
Cause: Rainfall
Discharge: Approximately 12,000 gallons discharged to Hot Springs Creek
Actions Taken: Hydro Cleaned, Environmental Cleanup
Code Red Issued: 5/7/2025
Code Red Cancelled: 5/13/2025

Lab Results

Sample Date:	5/7/2025	Sample Date:	5/9/2025	Sample Date:	5/12/2025
Site No.	E. coli (cfu)	Site No.	E. coli (cfu)	Site No.	E. coli (cfu)
1	1732.9	2	35.5	2	28.8
		3	17.1	3	12.1
		4	13.5	4	7.5

Code Red Signage Placed 5/7/2025 – Removed 5/13/2025



Site 1 Placed



Site 2 Placed




Site 1 Removed



Site 2 Removed

Environmental Cleanup Activities – Manhole 1866– 5/7/2025



MH 1866 Before cleanup



MH 1866 During cleanup



MH 1866 During Cleanup



MH 1866 After Cleanup

Environmental Cleanup Activities – Manhole 3728 – 5/7/2025



MH 3728 During Cleanup



MH 3728 After Cleanup

MAY SSO REPORT for Manholes 1866, 1865 and 3728 Hot Springs Creek Pump Station

Manhole 1866 **362 Fontana Road**
Overflow Date: 5/26/2025
End Date: 5/27/2025
Cause: Rainfall, Equipment
Discharge: Approximately 30,000 gallons discharged to Hot Springs Creek
Actions Taken: Hydro Cleaned, Environmental Cleanup
Code Red Issued: 5/26/2025
Code Red Cancelled: 6/1/2025

Manhole 3728 **107 Forest View Court**
Overflow Date: 5/26/2025
End Date: 5/27/2025
Cause: Rainfall
Discharge: Approximately 63,000 gallons discharged to Hot Springs Creek
Actions Taken: Hydro Cleaned, Environmental Cleanup
Code Red Issued: 5/26/2025
Code Red Cancelled: 6/1/2025

Manhole 1865 **352 Fontana Road**
Overflow Date: 5/26/2025
End Date: 5/26/2025
Cause: Rainfall, Equipment
Discharge: Approximately 54,000 gallons discharged to Hot Springs Creek
Actions Taken: Hydro Cleaned, Environmental Cleanup
Code Red Issued: 5/26/2025
Code Red Cancelled: 6/1/2025

Lab Results

Sample Date:	5/26/2025	Sample Date:	5/28/2025	Sample Date:	5/30/2025
Site No.	E. coli (cfu)	Site No.	E. coli (cfu)	Site No.	E. coli (cfu)
1	>2419.6	2	121.1	2	58.1
		3	52.9	3	48.8
		4	80.9	4	32.8

Code Red Signage Placed 5/26/2025 – Removed 6/1/2025




Site 1 Placed



Site 2 Placed



Site 1 Removed




Site 2 Removed

Environmental Cleanup Activities – Manholes 1866, 3728, and 1865 – 5/27/2025




MH 1866 Before cleanup



MH 1866 During cleanup



MH 1866 During Cleanup



MH 1866 After Cleanup


Environmental Cleanup Activities – Manholes 1866, 3728, and 1865 – 5/27/2025



MH 3728 Before Cleanup



MH 3728 During Cleanup



MH 3728 During Cleanup




MH 3728 After Cleanup

Environmental Cleanup Activities – Manholes 1866, 3728, and 1865 – 5/27/2025




MH 1865 Before Cleanup



MH 1865 During Cleanup



M MH 1865 During Cleanup



MH 1865 During Cleanup