



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/7/26 & 3/17/26

Location of event: Hot Springs Creek

Sample collection date: 3/25/26

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1133	E. Coli – 21.8 cfu per 100mls
Site 3:	1153	E. Coli – 6.3 cfu per 100mls
Site 4:	1156	E. Coli – 18.5 cfu per 100mls

On 3/24/26 and 3/25/26 sample results were below 630 cfu's per 100mls at each designated site. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs