



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901
Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 1/30/25

Location of event: Gulpha Creek

Sample collection date: 2/3/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0938	E. Coli – 387.3 cfu per 100mls
Site 3:	0954	E. Coli – 461.1 cfu per 100m
Site 4:	1001	E. Coli – 613.1 cfu per 100mls
Site 5:	1013	E. Coli – 172.6 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs