



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 1/30/25

Location of event: Gulpha Creek

Sample collection date: 2/4/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1012	E. Coli – 238.2 cfu per 100mls
Site 3:	1020	E. Coli – 547.5 cfu per 100m
Site 4:	1027	E. Coli – 410.6 cfu per 100mls
Site 5:	1036	E. Coli – 41.7 cfu per 100mls

On 2/3/25 and 2/4/25 test results were below 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5. No further testing is required.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs