



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 1/30/25

Location of event: Hot Springs Creek (Manhole 1865& 1866)

Sample collection date: 2/3/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1038	E. Coli – 547.5 cfu per 100mls
Site 3:	1046	E. Coli – 344.8 cfu per 100m
Site 4:	1054	E. Coli – 275.5 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, and site #4.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs