



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 10/28/25

Date and time of notification: 10/28/25 @ 1553

Location of event: Hot Springs Creek

Sample collection date and time: 10/28/25 @ 1731

Samples analyzed for: E.coli

ANALYSIS RESULTS

Site 1: E. coli – >2419.6 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue until two consecutive test results are below 630 cfu's at site #2, site #3, and site #4.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs