



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 11/25/25

Location of event: Hot Springs Creek

Sample collection date: 12/3/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1259	E. Coli – 48.1 cfu per 100mls
Site 3:	1310	E. Coli – 8.6 cfu per 100mls
Site 4:	1316	E. Coli – 4.1 cfu per 100mls

On 12/1/25 and 12/3/25 sample results were below 630 cfu's per 100mls at each designated site. No further testing is required.


Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs