



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901
Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 11/3/24 – 11/4/24

Location of event: Gulpha Creek

Sample collection date: 11/7/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1051	E. Coli – 113.0 cfu per 100mls
Site 3:	1059	E. Coli – 304.4 cfu per 100m
Site 4:	1107	E. Coli – 47.1 cfu per 100mls
Site 5:	1115	E. Coli – 101.7 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5.


Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs