



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 11/3/24 – 11/4/2024

Date and time of notification: 11/4/24 @ 0713

Location of event: Gulpha Creek (Manhole 1748)

Sample collection date and time: 11/4/24 @ 0816

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 2419.6 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, site 4 and site 5 until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs