



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 11/30/24

Location of event: Spencer's Bay (Manhole 8574) at 418 Essex Park Ter.

Sample collection date: 12/3/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1259	E. Coli – 13.4 cfu per 100mls
Site 3:	1308	E. Coli – 8.4 cfu per 100m
Site 4:	1312	E. Coli – 8.3 cfu per 100mls
Site 5:	1319	E. Coli – 13.2 cfu per 100mls

Test results were below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5 on 12/2/24 and 12/3/24. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs