



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 12/26/24

Location of event: Gulpha Creek

Sample collection date: 1/3/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 5:	1051	E. Coli – 7.4 cfu per 100mls

On 12/30/24 and 1/2/25 test results were below 630 cfu's per 100 mls at site #2, site #3, and site #4. On 1/2/25 and 1/3/25 test results were below 630 cfu's per 100 mls at site #5. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs