



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 2/11/25

Location of event: Gulpha Creek

Sample collection date: 2/14/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1051	E. Coli – 178.2 cfu per 100mls
Site 3:	1104	E. Coli – 198.9 cfu per 100m
Site 4:	1108	E. Coli – 139.6 cfu per 100mls
Site 5:	1115	E. Coli – 272.3 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5.


Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs