



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 2/11/25

Location of event: Gulpha Creek

Sample collection date: 2/17/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1004	E. Coli – 235.9 cfu per 100mls
Site 3:	1014	E. Coli – 93.3 cfu per 100m
Site 4:	1016	E. Coli – 152.9 cfu per 100mls
Site 5:	1027	E. Coli – 574.8 cfu per 100mls

On 2/14/25 and 2/17/25 test results were below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5. No further testing is needed.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs