



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 2/15/26 & 2/16/26

Location of event: Hot Springs Creek

Sample collection date: 2/20/26

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1346	E. Coli – 98.4 cfu per 100mls
Site 3:	1351	E. Coli – 51.2 cfu per 100mls
Site 4:	1356	E. Coli – 23.9 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, and site #4.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs