



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 2/15/26 & 2/16/26

Location of event: Hot Springs Creek

Sample collection date: 2/23/26

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

| <u>Site #</u> | <u>Time collected</u> | <u>Results</u>               |
|---------------|-----------------------|------------------------------|
| Site 4:       | 1258                  | E. Coli – 6.3 cfu per 100mls |

On 2/18/26 and 2/20/26 sample results were below 630 cfu's per 100mls at site #2 and site #3. On 2/20/26 and 2/23/26 sample results were below 630 cfu's at site #4. This satisfies the testing requirements.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs