

Kayla L. Grabinski

From: WW Lab <WWLab@cityhs.net>
Sent: Sunday, March 9, 2025 7:04 AM
To: Harold Mauldin; EE Water Enforcement Report; Leslie Allen-Daniel (adpce.ad); Monty Ledbetter; Bobby Harris; Shawn Davis; Howard Hoover
Subject: Fw: SSO Analysis Report for Hot Springs Creek 3/7/25
Attachments: doc00149020250309065740.pdf

Some people who received this message don't often get email from wwlab@cityhs.net. [Learn why this is important](#)

SSO Analysis Report for Hot Springs Creek 3/7/25 for overflow 3/4/25

From: Utilities57@cityhs.net <Utilities57@cityhs.net>
Sent: Sunday, March 9, 2025 6:57 AM
To: WW Lab <wwlab@cityhs.net>
Subject:

CS 3554ci
[d4:f0:c9:00:d3:22]



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/4/25

Location of event: Hot Springs Creek (Manhole 1865& 1866)

Sample collection date: 3/7/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0959	E. Coli – 410.6 cfu per 100mls
Site 3:	1007	E. Coli – 207.5 cfu per 100mls
Site 4:	1013	E. Coli – 344.8 cfu per 100mls

Results for samples taken on 3/6/25 & 3/7/25 were below the EPA recommended 630 cfu's per 100 mls at site #2, site #3, and site #4. No further testing is needed.

Tina Mietzner
Lab Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs