



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/4/25

Location of event: Hot Springs Creek (Manhole 1865& 1866)

Sample collection date: 3/6//25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1319	E. Coli – 228.2 cfu per 100mls
Site 3:	1325	E. Coli – 191.8 cfu per 100mls
Site 4:	1329	E. Coli – 163.8 cfu per 100mls

Testing will continue until two consecutive results are below 630 cfu's per 100 mls at site #2, site #3, and site #4.

Tina Mietzner
Lab Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs