



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/7/26

Location of event: Gulpha Creek

Date and time of notification: 3/7/26 @ 1108

Sample collection date and time: 3/7/26 @ 1225

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – >2419.6 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, site 4, and site 5 until two consecutive samples are below 630 cfu's per 100mls.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs