



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/7/26

Location of event: Gulpha Creek


Sample collection date: 3/16/26

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1310	E. Coli – 145.5 cfu per 100mls
Site 3:	1323	E. Coli – 238.2 cfu per 100m
Site 4:	1326	E. Coli – 71.2 cfu per 100mls
Site 5:	1334	E. Coli – 195.6 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5.


Amanda Cates

Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs