



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/7/26

Location of event: Gulpha Creek

Sample collection date: 3/18/26

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1344	E. Coli – 203.5 cfu per 100mls
Site 3:	1352	E. Coli – 87.3 cfu per 100m
Site 4:	1356	E. Coli – 43.9 cfu per 100mls
Site 5:	1403	E. Coli – 12.2 cfu per 100mls

On 3/16/26 and 3/18/26 test results were below 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5. October 1 thru April 30 the limit is 630 cfu's. No further testing is needed at this time.

A handwritten signature in black ink that reads "Amanda Cates".

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs