

Kayla L. Grabinski

From: Harold Mauldin <HMAuldin@cityhs.net>
Sent: Friday, April 11, 2025 1:55 PM
To: EE Water Enforcement Report; Leslie Allen-Daniel (adpce.ad)
Cc: Monty Ledbetter; Bobby Harris; Shawn Davis; Howard Hoover; 'Craig Johnson'; 'ellen carpenter'; Harry Elliott
Subject: Fw: CHS - SSO report Gulpha Creek
Attachments: doc00188220250411134621.pdf

Leslie,

See attached report for Gulpha Creek. No further testing is needed.

Harold Mauldin
Facilities Operations Manager
City of Hot Springs
(501) 621-5041 Ex. 2860



From: WW Lab <WWLab@cityhs.net>
Sent: Friday, April 11, 2025 1:49 PM
To: Harold Mauldin <HMAuldin@cityhs.net>
Subject: CHS - SSO report

Attached is a report for Gulpha Creek.

Amanda Cates
Laboratory Supervisor
wwlab@cityhs.net

From: Utilities57@cityhs.net <Utilities57@cityhs.net>
Sent: Friday, April 11, 2025 1:46 PM
To: WW Lab <wwlab@cityhs.net>
Subject:

CS 3554ci
[d4:f0:c9:00:d3:22]



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/2/25

Location of event: Gulpha Creek

Sample collection date: 4/10/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0947	E. Coli – 184.2 cfu per 100mls
Site 3:	0953	E. Coli – 81.6 cfu per 100mls
Site 4:	0958	E. Coli – 93.4 cfu per 100mls
Site 5:	1007	E. Coli – 30.5 cfu per 100mls

Results for samples taken 4/8/25 & 4/10/25 were below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5. No further testing needed.

A handwritten signature in black ink that reads "Amanda Cates".

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs