



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: This is additional testing for an overflow that started on 4/27/24 and has since ceased

Location of event: Gulpha (Manhole 1750)

Sample collection date and time: 5/2/24 @ 1020 – second time to test

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 63.7 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 126 cfu's per 100mls at designated Site #1. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs