

Kayla L. Grabinski

From: Harold Mauldin <HMAuldin@cityhs.net>
Sent: Tuesday, April 8, 2025 5:15 PM
To: EE Water Enforcement Report; Leslie Allen-Daniel (adpce.ad)
Cc: Monty Ledbetter; Bobby Harris; Shawn Davis; Howard Hoover
Subject: Fw: CHS - SSO report Hot Springs Creek
Attachments: doc00184020250408145642.pdf

Leslie,

See attached report for Hot Springs Creek. Testing will continue.

Harold Mauldin
Facilities Operations Manager
City of Hot Springs
(501) 621-5041 Ex. 2860



From: WW Lab <WWLab@cityhs.net>
Sent: Tuesday, April 8, 2025 2:58 PM
To: Harold Mauldin <HMAuldin@cityhs.net>
Subject: CHS - SSO report

Attached is a report for Hot Springs Creek.

Amanda Cates
Laboratory Supervisor
wwlab@cityhs.net

From: Utilities57@cityhs.net <Utilities57@cityhs.net>
Sent: Tuesday, April 8, 2025 2:56 PM
To: WW Lab <wwlab@cityhs.net>
Subject:

CS 3554ci

[d4:f0:c9:00:d3:22]



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/3/25

Location of event: Hot Springs Creek

Sample collection date: 4/7/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1324	E. Coli – 613.1 cfu per 100mls
Site 3:	1329	E. Coli – 488.4 cfu per 100mls
Site 4:	1335	E. Coli – 410.6 cfu per 100mls

Testing will continue until two consecutive results are below 630 cfu's per 100 mls at site #2, site #3, and site #4.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs