

## Kayla L. Grabinski

---

**From:** Harold Mauldin <HMAuldin@cityhs.net>  
**Sent:** Thursday, April 10, 2025 12:40 PM  
**To:** EE Water Enforcement Report; Leslie Allen-Daniel (adpce.ad)  
**Cc:** Monty Ledbetter; Bobby Harris; Shawn Davis; Howard Hoover  
**Subject:** Fw: CHS - SSO report Hot Springs Creek  
**Attachments:** doc00187620250410110429.pdf

Leslie,

See attached report for Hot Springs Creek. No Further testing is required.

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs  
(501) 621-5041 Ex. 2860



---

**From:** WW Lab <WWLab@cityhs.net>  
**Sent:** Thursday, April 10, 2025 11:07 AM  
**To:** Harold Mauldin <HMAuldin@cityhs.net>  
**Subject:** CHS - SSO report

Attached is a report for Hot Springs Creek.

Amanda Cates  
Laboratory Supervisor  
wwlab@cityhs.net

---

**From:** Utilities57@cityhs.net <Utilities57@cityhs.net>  
**Sent:** Thursday, April 10, 2025 11:04 AM  
**To:** WW Lab <wwlab@cityhs.net>  
**Subject:**

-----  
CS 3554ci

[d4:f0:c9:00:d3:22]

-----



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 4/3/25

Location of event: Hot Springs Creek

Sample collection date: 4/9//25

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

| <u>Site #</u> | <u>Time collected</u> | <u>Results</u>                |
|---------------|-----------------------|-------------------------------|
| Site 2:       | 0946                  | E. Coli – 51.2 cfu per 100mls |
| Site 3:       | 0953                  | E. Coli – 29.8 cfu per 100mls |
| Site 4:       | 0957                  | E. Coli – 57.1 cfu per 100mls |

On 4/7/25 and 4/9/25 test results were below 630 cfu's per 100 mls at site #2, site #3, and site #4. No further testing is requested.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs