



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/30/25 AND 5/6/25

Location of event: Gulpha Creek

Sample collection date: 5/14/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1203	E. Coli – 133.4 cfu per 100mls
Site 3:	1142	E. Coli – 579.4 cfu per 100m
Site 4:	1135	E. Coli – 91.1 cfu per 100mls
Site 5:	1128	E. Coli – 24.7 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs