



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/4/26

Location of event: Hot Springs Creek

Sample collection date: 4/9/26

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1354	E. Coli – 26.9 cfu per 100mls
Site 3:	1402	E. Coli – 31.1 cfu per 100mls
Site 4:	1406	E. Coli – 28.1 cfu per 100mls

On 4/7/26 and 4/9/26 sample results were below 630 cfu's per 100mls at each designated site. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs