



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/22/24

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 6/7/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0910	E. Coli – 76.3 cfu per 100mls
Site 3:	0918	E. Coli – 48.8 cfu per 100m
Site 4:	0923	E. Coli – 110.0 cfu per 100mls
Site 5:	0929	E. Coli – 18.3 cfu per 100mls

On 6/6/24 and 6/7/24 test results were below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5. No further testing is needed.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs