



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/23/24

Date and time of notification: 5/23/24 @ 1052

Location of event: Manhole 1754

Sample collection date and time: 5/23/24 @ 1234

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – >2419 cfu per 100mls
(Overflow Location)

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs