



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/26/25

Location of event: Hot Springs Creek

Sample collection date: 5/28//25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0923	E. Coli – 121.1 cfu per 100mls
Site 3:	0928	E. Coli – 52.9 cfu per 100mls
Site 4:	0934	E. Coli – 80.9 cfu per 100mls

Testing will continue until two consecutive results are below 126 cfu's per 100 mls at site #2, site #3, and site #4.



Steven Rynders
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs